



This report shows all the responses to the Fire Risk Assessment survey, including raised tasks.

Asset ID: 6486 **Glamis Walk, Hartlepool**

Cover Sheet

Photo



Date of Fire Risk Assessment	16 Oct 2025
Date of Next Fire Risk Assessment	16 Oct 2026
FRA Frequency (Months)	12
Purpose of Fire Risk Assessment	Annual Re-Assessment
Type of Fire Risk Assessment	Type 1 (Common Parts Only - Non Destructive)
Fire & Safety Assessor	Kevin Jones GFireE

It is sensible to have arrangements in place to ensure the consistency of Fire Risk Assessments in terms of the assessment of risk and mitigations proposed. In this regard Accent peer validate around 20% of reports, which are available within our audit system.

The Scheme

Scheme Name	Glamis Walk
Scheme Address	Glamis Walk, Hartlepool
Postcode	TS25 3JW
Region	North East
Scheme Manager	Claire Knaggs
Scheme Tel. No	
Scheme Inspection Completed	Yes
Enforcing Fire Authority	Cleveland fire authority
Other staff in attendance	None
Number of on-site Accent staff	Scheme Manager Weekdays
Number of other (non-Accent) staff	None

The Building

Accommodation Type	General Needs (S30)
Build Date	Jan 1 1990
Number Of Homes	51
Homes breakdown	Flat
External wall construction	Concrete Block, Facing Brick, Facing Brick, Facing Brick, Rendered Blockwork
External wall finish	Cement Render, Facing Brick, Paint Render
Roof construction	Timber
Roof covering	Interlocking Pitched
PEEPs in place where necessary	No
Current Evacuation Strategy	Stay Put (Delayed) Evacuation
Conversion or purpose-built	Purpose Built
Number of storeys	2
Number of floors on which car parking is provided	1
Is there a habitable basement?	No
Number of internal Staircases (protected or unprotected?)	1 protected per block
Number of External Staircases	0
External Balcony part of escape route?	No
Unusual features	None
Building Access Conditions for Fire Brigade	Vehicular Access to one or more elevations

Asset ID: 6486 Glamis Walk, Hartlepool

Fire Detection and Warning System	Flats and common areas not linked
Grade of fire alarm	Grade D
Category of fire alarm	LD3 Minimum Protection
Emergency Lighting Provision	Non Maintained System - Common Areas
Portable Fire Extinguishers supplied/fitted	No
Fixed Fire Fighting Installations	No

Customers

Number of occupants	20
Occupant tenure type breakdown	General Needs, Supported Housing

Fire Safety Related Customer Safety Servicing

Overdue communal gas safety checks	0
Overdue domestic gas safety checks	0
Overdue communal electrical condition checks	0
Overdue domestic electrical condition checks	0
Overdue alarm call pull chord tests	0
Overdue communal PAT testing	0
Overdue customer mobility scooter PAT testing	0
Overdue Monthly Emergency Lighting Switch Tests	0
Overdue Annual Emergency Lighting tests	0
Overdue Weekly Fire Alarm Testing	0
Overdue Fire Panel - Six Monthly Testing	
Overdue Fire Safety Equipment tests	

Building Fire Safety Surveys - Communal Doors

Failing Communal Fire Doors	0
Communal Fire doors due for replacement within 5 years	0

Dwelling Doors

Failing Dwelling Fire Doors	0
Dwelling Fire doors due for replacement within 5 years	0

Fire Risk Assessment Survey Results

Scheme and Building Information

Photo



Date of Fire Risk Assessment	16/10/2025
FRA Frequency (Months)	12
Purpose of Fire Risk Assessment	Annual Re-Assessment
Type of Risk Assessment	Type 1 (Common Parts Only - Non Destructive)
Quantity	1
Fire & Safety Assessor	Kevin Jones GIFireE
Enforcing Fire Authority	Cleveland fire authority
Scheme Tel. No	
Other staff in attendance	None
Number of on-site Accent staff	Scheme Manager Weekdays
Number of other (non-Accent) staff	None
Scheme Inspection completed	Yes
Number of occupants	20
Personal Emergency Evacuation Plans in place	No
Current Evacuation Strategy	Stay Put (Delayed) Evacuation
Conversion or purpose-built	Purpose Built
Number of Storeys	2
Number of floors on which car parking is provided	1
Is there a habitable basement?	No
No. of internal staircases (protected/unprotected)	1 protected per block
Number of external staircases	0
External balcony part of escape route?	No
Unusual features	None

Fire Risk Assessment Survey Results

Building access conditions for Fire Brigade

Vehicular Access to one or more elevations

Surroundings: Residential/Commercial

Mixed

Fire Detection and Warning System

Flats and common areas not linked

Grade of Fire Alarm

Grade D

Category of Fire Alarm

LD3 Minimum Protection

Emergency Lighting Provision

Non Maintained System - Common Areas

Portable Fire Extinguishers / Fire Blankets supplied / fitted

No

Water Extinguisher(s) present

No

Foam Extinguisher(s) present

No

Dry Powder Extinguisher(s) present

No

Carbon Dioxide Extinguisher(s) present

No

Fire Blanket(s) present

No

Fixed Fire Fighting Installations supplied / fitted

No

Dry Riser(s) present

No

Wet Riser(s) present

No

Sprinkler System present

No

Hosereel(s) present

No

Automatic Opening Vent(s) present

No

Electrical Sources of Ignition

Electrical installation within common areas in good condition and no obvious damage?

Yes

Comment

All blocks appear to be in good condition and secured

Valid Electrical Installation Condition Reports held on file? (Common Areas & General Needs Flats)

Yes

Comment

Results uploaded to Active H

Electrical App/PA Testing - tested within past 12 months?

N/A

Comment

No portable appliance evident in any blocks during assessment

Absence of trailing leads and adapters?

N/A

Comment

Evidence that mobility scooters are not being stored/charged in common areas?

No

Comment

Is there a purpose built mobility scooter store/charging area?

No

Comment

Does the building have a lightning protection system?

No

Comment

Not required for the height of this building

Comment

Observation	Priority	Referred To	Required By:	Task ID
Chipboard left in electrical in take cupboard in block 5 - 6	Internal - Medium	Housing Partner	14/11/2025	2034958
				

Gas installations

Is there a commercial/domestic gas supply to the scheme?

Yes

Comment

Flats only no communal supply

Valid LGSR held on file for fixed communal area gas appliances?
(Boilers)

N/A

Comment

No gas supply in communal areas

Valid LGSR held on file for residential flats that contains gas appliances?

Yes

Comment

Results are uploaded to Active H

Are smoke/heat detectors within General Needs flats subject to an annual inspection and the results

Yes

Comment

All results of testing is uploaded and stored in Active H

Other Sources of Ignition

Is there a no smoking policy in place, which is enforced and adhered to?

Yes

Comment

Communal areas only customers are permitted to smoke inside flats

Adequate security against arson?

Yes

Comment

Fob front entrance and key operated rear door all secure at time of assessment

Are refuse/recycling bin areas managed and suitably located?

Yes

Comment

Designated refuse bin storage areas to the front of the building a satisfactory distance from the building

Are there communal cooking facilities at this scheme?

No

Comment

Housekeeping

Are all electrical/intake/service cupboards secure and free from general waste, contractors waste and residents personal items?

No

Comment

Electrical intake cupboard within block 5- 6 has chipboard stored inside. Email sent to SHP on 16/10/2025 requesting removal.

Are unnecessary accumulations of combustible materials or waste avoided?

Yes

Comment

Sterile communal areas identified in all blocks

Are combustible materials and substances separated from ignition sources and stored appropriately?

Yes

Comment

Furniture/furnishings in good condition, fire retardant/resistant and comply with modern standards and regulations?

N/A

Comment

No furniture supplied in communal areas.

Other Significant Fire Hazards

Are all other significant fire hazards adequately controlled?

Yes

Comment

Means of Escape from Fire

Is it considered that the building is provided with reasonable means of escape in case of fire?

Yes

Comment

Single direction MOE from 1st floor 2 directional MOE on ground floor.

Escape routes unobstructed and safe to use?

No

Comment

Electrical intake cupboard in block 1 - 2a has a faulty door closer, repair requested 16/10/2025 works order no.1318969

Exits immediately openable without a key and/or failsafe's function correctly?

Yes

Comment

All blocks have thumb turn furniture to rear exit doors and electronic push button operation to the front doors.

Reasonable distances of travel where there is a single/alternative direction of travel?

Yes

Comment

Minimal travel distances

Escape routes lead to final exits and open in direction of escape where necessary?

Yes

Comment

Fire Spread and Development

Is it considered that the compartmentation is of a reasonable standard?

Yes

Comment

Purpose built blocks.

Is there reasonable limitation of surface finishes that might promote fire spread (walls, floors, ceilings)?

Yes

Comment

Plaster finish walls and ceilings clear of all materials

Are fire dampers/shutters provided in ducts/refuse chutes to protect means of escape against fire, smoke and combustion products?

N/A

Comment

As far as can be reasonably ascertained, is the compartmentation within roof spaces of a satisfactory standard?

Yes

Comment

Sample inspection carried out compartmentation appears to be of correct standards

Loft hatches fire resisting?

Yes

Comment

As far as can be reasonably ascertained, is the fire stopping above cross corridor fire doors within suspended ceiling void of a satisfactory standard?

N/A

Comment

No cross corridors fitted in building

Do external walls, doors, windows and anything attached to the exterior, limit fire spread?

Yes

Comment

Traditional construction, brick and mortar concrete floors and plaster finish walls and ceilings

If Smoke Control Systems (AOV's) are fitted, are the records of annual testing available?

N/A

Comment

None fitted

Are roller shutter doors that are required to be FR, fire resisting and self-closing?

N/A

Comment

None fitted

Observation	Priority	Referred To	Required By:	Task ID
Designated refuse store	No Action			
				

Emergency Escape Lighting

Is the emergency lighting correctly specified and installed as per current standards?

Yes

Comment

Appears to be installed to correct standards

Emergency lighting units in good condition and securely fixed to walls/ceilings?

Yes

Comment

All lighting appears to be in good condition and secured

Records of monthly/annual testing available?

Yes

Comment

Results are uploaded to Active H

Observation	Priority	Referred To	Required By:	Task ID
Lighting in good condition and secured	No Action			
				

Fire Safety Signs and Notices

Are the correct Fire Action/Advice notices displayed in prominent locations within the common areas?

Yes

Comment

Positioned correctly throughout all blocks

Directional fire escape signage in place and adequate?

Yes

Comment

Single directional MOE from 1st floor and 2 way MOE on ground floor

Is there suitable LIFT signage i.e. do not use in case of fire?	N/A
Comment	No lift
Do common area fire doors display the correct signage on both sides where applicable?	Yes
Comment	Under stairs electrical intake cupboard doors in all blocks.

Observation	Priority	Referred To	Required By:	Task ID
Correctly positioned signage	No Action			
				

Means of giving Warning in case of Fire

Is the scheme fitted with a communal area fire alarm?	Yes
Comment	
Is fire detection and warning system appropriate for occupancy and fire risk, as per BS 5839-1:2017?	Yes
Comment	
Is the fire detection and warning system maintained/tested and all certificates saved on file?	Yes
Comment	Results are uploaded and stored on Active H
Fire alarm components in good condition and securely fixed to walls/ceilings?	Yes
Comment	All detectors in each block are to be of good condition and secured
Hold open devices operate at the sounding of the alarm and are in a serviceable condition?	N/A
Comment	None fitted
Are there heat detectors located in the Kitchen, Boiler, Plant Room and Laundry?	Yes
Comment	
Is the fire alarm panel remotely monitored, and if so are there records of regular testing?	N/A
Comment	Not remotely monitored

Observation	Priority	Referred To	Required By:	Task ID
Detectors in good condition and secured	No Action			
				
				

Fire Extinguishing Equipment

Is fire extinguishing equipment and/or fixed fire fighting installations provided at this scheme?	No
Comment	

Management of Fire Safety

Are these premises regulated by the Building Safety Regulator under the Building Safety Act?	No
Comment	
Are there other Responsible Persons who share or have fire safety duties in respect of the premises?	No
How will this sharing be achieved?	
Is an office or IL scheme being inspected?	No
Comment	

Passenger Lift

Is the scheme fitted with a passenger lift?	No
Comment	

Premises Inspection Box

Is there a premises information box for fire & rescue service use?	No
Comment	Not required for General needs customers

Evacuation Policy

Are there suitable arrangements for summoning the fire service?

Yes

Comment

999 call from customers

Taking FRA findings, is the evacuation policy appropriate for the scheme as per latest guidance?

Yes

Comment

Purpose built flats

Engagement with Residents

Has information of fire procedures been disseminated to residents?

Yes

Comment

During the induction programme and via customer portals

Is general fire safety information disseminated to residents?

Yes

Comment

Customer portal

FRA Frequency

Taking the findings of this assessment into account, is the frequency of the FRA correct?

Yes

Comment

Transient customers and evidence of ASB

Miscellaneous

Are there any other observations/actions to raise that are not covered above.

No

Are there fire related remedial works required at this property, that will affect the fabric of the building?

Yes

Comment

Chip board left in electrical cupboard in block 5 -6 and door closer required for electrical intake cupboard in block 1 - 2

Can work be conducted without the need for an asbestos survey. If no, task Customer Safety Surveyor - Asbestos.

Yes

Comment

Were there any unsatisfactory aspects of the Fire Risk Assessment? (Visible on Building Safety Report).

Yes

Some fire doors did not fully close so works orders have been raised with our contractors.

No

Some minor works were required which have been raised with our contractors.

Yes

Unauthorised items were found in communal areas and arrangements were made for their removal.

Yes

Not all records were up to date, as noted in the table below. Arrangements have been made for these to be completed.

No

A number of fire doors were found to be wedged or propped open. Fire doors are there to keep you safe and me kept shut at all times.

No

Risk Calculator - Fire

The following risk estimator is based on the general health and safety risk level estimator contained within BS 8800: 1996. Guide to occupational health and safety management systems.

1. Taking into account the fire prevention measures observed at the time of this risk assessment, it is considered that the hazard from the fire (the probability of ignition) at this building is:

LOW



MEDIUM



HIGH



2. Taking into account the nature of the building, the occupants, the fire protection afforded and any procedural arrangements observed at the time of the assessment, it is considered that the consequences for life safety in the event of a fire would be:

MINOR



MAJOR



CRITICAL



The definition of the above terms is as follows:

FRA Review Frequency

MINOR	Outbreak of fire is unlikely to result in serious injury or death of any occupant (other than the occupant sleeping in a bedroom in which a fire occurs).
MAJOR	An outbreak of fire could result in injury of one or more occupants, but is unlikely to lead to fatalities.
CRITICAL	There is significant potential for serious injury or death of one or more occupants.

3. The above estimates are then read into the following matrix table to give the overall risk level for the site:

Fire Hazard	Minor	Major	Critical
Low	Trivial	Tolerable	Moderate
Medium	Tolerable	Moderate	Substantial
High	Moderate	Substantial	Intolerable

When the level of risk is established, the action level can be read from the table below:

Risk Level	Guide to actions and appropriate timescales
Trivial	No action is required
Moderate	Efforts should be made to reduce the risk level and this should be carried out within the specified time periods.
Substantial	Considerable resources may have to be allocated to reduce the risk level. It may be necessary to limit the occupation of some parts until urgent remedial action is taken.
Intolerable	The building (or the relevant area) should not be occupied until the risk is reduced.

The Overall Risk Level for this asset is:

Trivial