

ACCENT HOUSING - FIRE RISK ASSESSMENT



Region :	East
Scheme Name :	INGLEBOROUGH
Scheme Address :	Alma Road Peterborough PE1 3BY
Date of Assessment:	05/11/2025
Date of Next Assessment:	04/11/2028
FRA Frequency:	3 Year Re-Assessment
Fire & Safety Assessor	Lynn Betteridge

This Fire Risk Assessment has been conducted upon the instruction of Accent Housing.

Scheme Details		INGLEBOROUGH	
Region:		East	
Scheme Name:		INGLEBOROUGH	
Site Address:	Street:	Alma Road	
	Town:	Peterborough	
	Post Code:	PE1 3BY	
Block & Asset No.		1-6	Asset 696
Block & Asset No.		7-12	Asset 697
Block & Asset No.		13-18	Asset 698
Scheme Tel. No:			
Date of this Assessment		05/11/2025	
Date of Next Review		04/11/2028	
Fire Risk Assessment Frequency		3 Years	
Purpose of Fire Risk Assessment		3 Year Re-Assessment	
Fire & Safety Assessor		Lynn Betteridge	
Director of Customer Experience			
Customer Partnership Manager		Alan Percival	
Contract Manager			
Scheme Manager/Customer Partner		Kirsty Cox	
Other staff in attendance		None	
Use of Building		General Needs	
Approximate Number of occupants		25	
Occupancy Profile		Families	
Familiarity of the occupants		Fully Familiar	
Likely state of the Occupants		Alert	
PEEPs in place where necessary		No	
Number of on-site Accent staff		None	
Number of other (non-Accent) staff		Contract cleaners in common areas	
Support Agency (Supported Housing)		N/A	
Current Evacuation Strategy.		Stay Put (Delayed) Evacuation	
Evidence that residents have been notified of the evacuation procedure		Advice notices displayed in common areas	
History of fires in the building		None	
Business Continuity Plan in place?		Yes	
Scope of Assessment		Type 1 (Common Parts Only - Non Destructive)	
Applicable Fire Safety Guidance		Purpose-built flats guide	

Building Details	INGLEBOROUGH
Construction Date	1990s
Construction Type	Joisted or Load Bearing Masonry (Traditional)
Roof Finish	Pitched-Concrete Tile
External Wall Finish	Brick
Are there any areas of external wall cladding	No
Are there any balconies	No
Conversion or purpose-built	Purpose Built
Number of flats (self-contained)/rooms (HMOS, shared houses)	18
Number of storeys above ground	Two
Number of storeys below ground	None
Is there a habitable basement?	No
Number of internal Staircases per Block (protected or unprotected?)	One-Protected
Number of External Staircases per Block	None
External Balcony part of escape route?	No
Unusual features	None
Building complexity	Simple
Building Access Conditions for Fire Brigade	Vehicular Access to one or more elevations
Surroundings: Residential/Commercial	Residential
Fire Provision Currently in Place	
Fire Detection and Warning System	Flats only
Grade of fire alarm	Grade D
Category of fire alarm	LD3 Minimum Protection
Additional Comments:	
Evacuation Alert System (EAS)	Yes-Alarm Sounder
Additional Comments:	
Emergency Lighting Provision	Maintained system - Common Areas
Additional Comments:	
Portable Fire Extinguishers	None fitted
Additional Comments:	
Fixed Fire Fighting Installations	None fitted
Additional Comments:	

Significant Findings - Fire						
INGLEBOROUGH				05/11/2025		
Action Ref:	Potential Area of Fire Risk	Yes-No-N/A	Observation/Comments/ Actions Required	Risk Rating	Target Completion Date	ActionTaken
Fire Hazards						
1	Electrical Sources of Ignition:					
1.1	Electrical Installation within common areas (Fixed Wiring, sockets, switches, light fittings) in good condition and no obvious damage	Yes	All common area sockets and fittings in a satisfactory condition at the time of inspection.	.		
1.2	Valid Electrical Installation Condition Reports held on file.(Common Areas)	Yes	Valid communal area EIC Reports for all blocks uploaded to active H and M files..	.		
1.3	Valid Electrical Installation Condition Reports held on file. (General Needs Flats)	Yes	Valid General Needs flats EIC Reports uploaded to Active H and M files.	.		
1.4	Electrical App/PA Testing - all portable appliances tested within past 12 months	N/A	PAT not required, no portable electrical equipment in communal areas	.		
1.5	Absence of trailing leads and adapters	Yes		.		
1.6	Mobility Scooters - Stored/charged in common areas, purpose built store/resident flat	N/A	No evidence or reports that any of the residents own a mobility scooter	.		
2	Smoking:					
2.1	Are there any risks associated with smoking in the building?	Yes	There is no smoking allowed within communal areas but residents are allowed to smoke within their flats	Low		
3	Arson:					
3.1	Adequate security against arson?	Yes	Building secure - Intercom door entry system with trade button access.	.		
3.2	Is there an absence of unnecessary fire load in close proximity to building?	Yes		.		

4	Heating Installations (Portable/fixed) Gas Installations - Common Areas & General Needs Residential flats.				
4.1	If portable heaters are used, are there suitable controls?	N/A		.	
4.2	Are fixed heating installations subject to regular maintenance?	Yes		.	
4.3	Valid LGSC held on file for each residential flat that contains gas appliances.	Yes	Gas supplied to this scheme.	.	
5	Cooking:				
5.1	Are reasonable measures taken to prevent fires as a result of cooking?	N/A		.	
5.2	Where there is extraction ventilation in communal kitchens are filters changed/ cleaned and ductwork cleaned regularly?	N/A		.	
6	Lightning Protection System:				
6.1	Does the building have a lightning protection system, If so, is it adequately maintained?	N/A		.	
7	Housekeeping:				
7.1	Is the standard of housekeeping adequate?	Yes	Communal areas were clear at the time of inspection	.	
7.2	Are all electrical/intake/service cupboards secure and free from general waste, contractors waste and residents personal items.	Yes		.	
7.3	Are combustible materials separated from ignition sources and stored appropriately?	Yes	None found at the time of inspection	.	
7.4	Are unnecessary accumulations of combustible materials or waste avoided?	Yes	None found at the time of inspection	.	
7.5	Are hazardous materials stored appropriately (i.e. oxygen cylinders, flammable materials, explosive products, oxidising products, aerosols)	N/A		.	
8	Furniture/furnishings on escape routes and other communal areas:				

8.1	Furniture/furnishings in good condition, fire retardant and complies with 1988 Regulations.	N/A		.		
9 Other Significant Fire Hazards:						
9.1	Are there other significant fire hazards that are inadequately controlled?	No		.		
Fire Protection Measures						
10 Means of Escape from Fire:						
10.1	Is it considered that the building is provided with reasonable means of escape in case of fire?	Yes		.		
10.2	Escape routes unobstructed and safe to use?	Yes	All clear at the time of inspection.	.		
10.3	Exits easily and immediately openable where necessary, without a key?	Yes		.		
10.4	Reasonable distances of travel where there is a single/alternative direction of travel?	Yes		.		
10.5	Escape routes lead to final exits and open in direction of escape where necessary?	Yes		.		
10.6	Do failsafe's on locked exit doors function correctly?	Yes		.		
10.7	Is it considered that the building is provided with reasonable arrangements for means of escape for disabled people?	Other	Only from the ground floor flats this scheme has disabled ramps to each Block.	.		
11 Measures to Limit Fire Spread and Development:						
11.1	Is it considered that the compartmentation is of a reasonable standard?	Yes		.		
11.2	Is there reasonable limitation of surface finishes that might promote fire spread (walls, floors, ceilings)?	Yes		.		
11.3	Are fire dampers/shutters provided in ducts/refuse chutes to protect means of escape against fire, smoke and combustion products?	N/A		.		

11.4	Compartmentation within roof spaces of a satisfactory standard?	N/A		.		
11.5	Loft hatches fire resisting?	N/A		.		
11.6	Fire stopping above cross-corridor fire doors within suspended ceiling void of a satisfactory standard	N/A		.		
11.7	Smoke Control Systems (AOV's) Are records of annual testing available?	N/A		.		
11.8	Roller shutter doors (fire resisting)	N/A		.		
11.9	Do the external walls, windows, balconies etc pose a risk of significant fire spread?	N/A		.		
12	Communal Area Fire Doors (Inspection to include - construction, hinges, closure devices, intumescent/smoke seal condition, glazing systems and maximum gaps between door and frame.					
12.1	Communal fire doors to FD30s standard and in a serviceable condition,	Yes		.		
12.2	"Fire door keep shut/locked" signage displayed on both sides of all applicable doors.	Yes		.		
12.3	Hold open devices operate at the sounding of the alarm and are in a serviceable condition	N/A		.		
13	Flat entrance doors (Internal Common Areas)					
13.1	Do flat entrance doors open onto internal escape routes?	Yes	Flat doors open to smoke lobby and communal fire door.	.		
14	Flats with a single direction of escape to a single escape stairway. (External Balcony)					
14.1	Do the flat entrance doors that open onto an external balcony have to be passed during an escape?	N/A		.		
14.2	Are the separating walls between the flats and the balcony floor that have to be passed during an escape, fire-resisting up to a height of 1.1m?	N/A		.		
15	Emergency Escape Lighting:					

15.1	Is the emergency lighting correctly specified and installed as per BS 5266-1:2016	Yes		.		
15.2	Are all emergency lighting units in good condition and securely fixed to walls/ceilings	Yes	All in good condition at the time of inspection	.		
15.9	Are records of monthly testing available?	Yes	All records are available on ActiveH and M files.	.		
15.10	Are records of annual testing available?	Yes	All records are available on ActiveH and M files.	.		
16	Fire Safety Signs and Notices:					
16.1	Are the correct Fire Action/Advice notices displayed in prominent locations within the common areas?	Yes	Note: Fire routine notices adjacent to final exit.	.		
16.3	Directional fire escape signage in place and adequate?	Yes		.		
16.4	Is there a suitable LIFT sign i.e. do not use in case of fire.	N/A		.		
17	Means of giving Warning in case of Fire:					
17.1	Is the fire detection and warning system appropriate for the occupancy and fire risk?	Yes		.		
17.2	Is the fire detection and warning system correctly specified and installed as per BS 5839-1:2017	Yes		.		
17.3	Is the fire detection and warning system maintained/tested and all certificates saved on file. (BS 5839-1:2017)	Yes		.		
17.4	Are there heat detectors located in the Kitchen, Boiler, Plant Room and Laundry?	N/A		.		
17.5	Is the fire alarm panel remotely monitored, and if so are there records of regular testing?	N/A		.		

17.6	Are smoke/heat detectors within General Needs flats subject to an annual inspection and the results recorded on an in date Landlord Gas Safety Record (LGSR)	Yes	All records are available on ActiveH and M files sample flat taken and recorded Flat 4 Asset 1513 test date 5/6/25 and all detectors checked.	.		
18	Fire Extinguishing Equipment:					
18.1	Portable fire extinguishers - appropriate type/number/position?	N/A		.		
18.2	Correct signage displayed by each fire extinguisher?	N/A		.		
18.3	Fire blanket in communal kitchen, secured to the wall, complete with signage?	N/A		.		
18.4	Hose Reels - fitted, maintained?	N/A		.		
18.5	Dry/wet risers - Full access to all inlet/outlet boxes. All inlet/outlets secured and/or securing straps fitted to outlet valves?	N/A		.		
18.6	Records available of fire fighting equipment servicing within past 12 months	N/A		.		
19	Management of Fire Safety					
19.1	Are there suitable arrangements for summoning the fire service?	Yes	Residents are advised to contact the fire service by dialing 999	.		
19.2	Do relevant staff carry out regular fire safety checks	Yes	Scheme Housing partner carry out inspections.	.		
19.3	Sheltered Schemes & Regional Offices - Are there sufficient number of qualified Fire wardens.	N/A		.		
19.4	Offices - Are there suitable arrangements for ensuring the premises are evacuated?	N/A		.		
19.5	Offices - Are there suitable arrangements for evacuating disabled people?	N/A		.		

19.6	Offices - Are there suitable arrangements for meeting the fire service on arrival and providing relevant information?	N/A		.		
19.7	Offices/IL Schemes - Is there a suitable assembly point?	N/A		.		
19.8	Offices - Are fire drills carried out at appropriate intervals?	N/A		.		
20	Evacuation Policy					
20.1	Taking the findings of the FRA into account, is the evacuation policy appropriate for the scheme?	Yes		.		
21	Miscellaneous					

Residents Front Doors						
INGLEBOROUGH					05/11/2025	
Flat entrance doors to FD30s specification (Inspection to include - Door condition, construction, closure devices, intumescent/smoke seal condition, glazing systems, fire rated letterplate, door furniture and maximum gaps between door and frame/threshold.						
Flat No.	Access Gained	Asset No.	Observation/Comments / Actions Required	Risk Rating	Completion Date	Action Taken
4	Yes	1513	Satisfactory	Low		
6	Yes	1515	Satisfactory	Low		
7	No	1516	No Access Visual inspection	Low		
8	Yes	1517	Satisfactory	Low		
10	No	1519	No Access Visual inspection	Low		
12	Yes	1521	No Access Visual inspection	Low		
14	No	1523	No Access Visual inspection	Low		

Photographs - Fire

05/11/2025

INGLEBOROUGH



Photo No. 1

Communal Fire Doors first Floor.



Photo No. 2

Main Access Door

Photographs - Fire	
05/11/2025	INGLEBOROUGH




Photo No. 3	Ground Floor Main access and egress.
-------------	--------------------------------------



Photo No. 4	Roof light 3rd Floor.
-------------	-----------------------

Photographs - Fire

05/11/2025

INGLEBOROUGH




Photo No. 5

Second floor to 3rd floor.

6. Risk Calculator - Fire

The following risk estimator is based on the general health and safety risk level estimator contained within BS 8800: 1996. Guide to occupational health and safety management systems.

1. Taking into account the fire prevention measures observed at the time of this risk assessment, it is considered that the hazard from the fire (the probability of ignition) at this building is:

(please insert x below)

LOW ☒ MEDIUM ☐ HIGH ☐

2. Taking into account the nature of the building, the occupants, the fire protection afforded and any procedural arrangements observed at the time of the assessment, it is considered that the consequences for life safety in the event of a fire would be:

(please insert x below)

MINOR ☐ MAJOR ☒ CRITICAL ☐

The definition of the above terms is as follows:

FKA Review Frequency

MINOR	Outbreak of fire is unlikely to result in serious injury or death of any occupant (other than the occupant sleeping in a bedroom in which a fire occurs).
MAJOR	An outbreak of fire could result in injury of one or more occupants, but is unlikely to lead to fatalities.
CRITICAL	There is significant potential for serious injury or death of one or more occupants.

3. The above estimates are then read into the following matrix table to give the overall risk level for the site:

Fire Hazard	Minor	Major	Critical
Low	Trivial	Tolerable	Moderate
Medium	Tolerable	Moderate	Substantial
High	Moderate	Substantial	Intolerable

When the level of risk is established, the action level can be read from the table below:

Risk Level	Guide to actions and appropriate timescales
Trivial	No action is required
Moderate	Efforts should be made to reduce the risk level and this should be carried out within the specified time periods.
Substantial	Considerable resources may have to be allocated to reduce the risk level. It may be necessary to limit the occupation of some parts until urgent remedial action is
Intolerable	The building (or the relevant area) should not be occupied until the risk is reduced.